


EATON COOPER LOAD CONTROL SWITCH
 MODEL #6700RFN 2 OR 3 FUNCTION



- Blue Wires – 30 Amp N.C. dry contact
- Yellow Wire – 5 Amp N.C. dry contact
- Orange Wires – 30 Amp N.C. dry contact
- Red
Black } 240 V.A.C. POWER

1. Wright Hennepin Cooperative Electric Association will not be responsible or liable for any personal injury or property damage in the wiring of or the operation of this or any Energy saving Program. Wright Hennepin recommends the use of a licensed electrical contractor.
2. All wiring must meet N.E.C. (National Electrical Code) and be inspected by a state electrical inspector before Wright Hennepin will check out installation, credit KWH usage or issue any applicable rebates.
3. Any time power is off & restored to the load control switch, there will be a 15 minute time delay before unit will be allowed to operate.
4. Load control switch/meter socket must be mounted 4' to 6' above the ground outside of all structures with ample access around unit.
5. A red light indicates that a load is being controlled.
6. A green and amber lights indicates power to control switch.
7. Two or three function.

 <p>WRIGHT-HENNEPIN COOPERATIVE ELECTRIC ASSOCIATION</p>		<p>ENERGY AND SERVICES DEPARTMENT 1-800-943-2667</p>	
		<p>EATON LOAD CONTROL SWITCH</p>	
DATE	5/6/2024	DWG BY:	LM1B
PROJECT NO.		SCALE	N/A
		CHKD BY:	
		APPD BY:	
		SHEET	1 OF 1