


EATON COOPER SINGLE FUNCTION LOAD
CONTROL SWITCH
MODEL #6200 RFN

EATON
LOAD CONTROL
SWITCH




R1 ELECTRIC HEAT, ELECTRIC CAR OR AIR
CONDITIONING. WHEN THE LIGHT IS ON THE
LOAD IS OFF.

Yellow Wire – 5 Amp N.C. dry contact

Red
Black } 240 V.A.C. POWER

1. Wright Hennepin Cooperative Electric Association will not be responsible or liable for any personal injury or property damage in the wiring of or the operation of this or any Energy saving Program. Wright Hennepin recommends the use of a licensed electrical contractor.
2. All wiring must meet N.E.C. (National Electrical Code) and be inspected by a state electrical inspector before Wright Hennepin will check out installation, credit KWH usage or issue any applicable rebates.
3. Any time power is off & restored to the load control switch, there will be a 15 minute time delay before unit will be allowed to operate.
4. Load control switch/meter socket must be mounted 4' to 6' above the ground outside of all structures with ample access around unit.
5. A red light indicates that a load is being controlled.
6. A green light indicates power to control switch.

 <p>Wright-Hennepin Cooperative Electric Association A Touchstone Energy® Cooperative</p>		<p>WRIGHT-HENNEPIN COOPERATIVE ELECTRIC ASSOCIATION</p> <p>ENERGY AND SERVICES DEPARTMENT 1-800-943-2667</p> <p>EATON SF LOAD CONTROL SWITCH</p>							
				DATE	4/19/2024	DWG BR:	TLG	DWG NO.	
PROJECT NO.		SCALE	N/A	CHKD BR:		APPD BR:		SHEET	1 OF 1